

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/20/2007
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 344002	(X2) MULTIPLE CONSTRUCTION A. BUILDING 03 - HOEY B. WING _____		(X3) DATE SURVEY COMPLETED 08/23/2007
NAME OF PROVIDER OR SUPPLIER BROUGHTON HOSP			STREET ADDRESS, CITY, STATE, ZIP CODE 1000 S STERLING ST MORGANTON, NC 28655		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 020	<p>NFPA 101 LIFE SAFETY CODE STANDARD</p> <p>Stairways, elevator shafts, light and ventilation shafts, chutes, and other vertical openings between floors are enclosed with construction having a fire resistance rating of at least one hour. An atrium may be used in accordance with 8.2.5.6. 19.3.1.1.</p> <p>This STANDARD is not met as evidenced by: Based on observation, on August 23, 2007 at approximately 9:30am onward, the fire rated enclosure is incomplete at pipe chase behind lavatories in shower room 254. The enclosure is not equipped with a fire rated door assembly where access is provided to chase.(W Ward - Hoey Bldg)</p>	K 020			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.